

Test report

No. 2011-B-3797/1

1. Official copy

Customer:	RZ-Products GmbH Industriestrasse 41 D-57518 Betzdorf
Order content:	To perform a fire resistance test on a Type B data security room in the multifunction oven with four-sided firing as per the uniform-temperature-time-curve (UTTC).
Test principles:	DIN EN 1047-2:2010-04; DIN EN 1363-1:1999-10
Test object /manufacturer designation:	GRANITE-ROOM.cert
Nature of test object	Data security room Type B
Order dated:	05.09.2011
Test date:	11.02.2011
Sampling:	Details on an official sampling of the materials supplied are not available to MPA Dresden GmbH
Scope of test report:	12 pages of text and 50 pages of appendices

This test report is written in a English version. If there is any doubt only the German version of test report 2011-B-3797/1 shall prevail



The publishing of test reports, even extracts therefrom, and references to tests for the purposes of advertising require the written consent of MPA Dresden GmbH in each individual case. The individual pages of this test report have been endorsed with the official stamp of the company MPA Dresden GmbH.

MPA Dresden GmbH
Fuchsmühlenweg 6F
09599 Freiberg
Tel. +49(0)3731-20393-0
Fax +49(0)3731-20393110

Geschäftsführer: Thomas Hübler
Steuernummer: 220/114/03011
Amtsgericht Chemnitz HR B 21581
www.mpa-dresden.de
Email info@mpa-dresden.de

Sparkasse Mittelsachsen
Poststraße 1a
09599 Freiberg
Kto. 3115024672
BLZ 870 520 00

USt-IdNr. DE234220069
IBAN DE68 8705 2000 3115 0246 72
BIC WELADED1FGX