

# Test Report

**No2012-02110**

**Order No** 1202267

**Customer** RZ - Products GmbH, Industriestraße 41,  
D-57518 Betzdorf, Germany

**Manufacturer** RZ - Products GmbH, Industriestraße 41,  
D-57518 Betzdorf, Germany

**Specimen** Data security room

**Type reference** GranITe-Room.cert

**Date of delivery** 2012-11-12

**Test Specification** EN60529:1991 + A1:2000


**Tests conducted** Verification of degree of protection:  
  
IP4X (test probe, 1mm)  
IP5X, cat.2 (dust chamber)  
IPX6 (water jet)


**Test results** IP56 passed

**Number of pages (total)** 13 (1 cover sheet 12 documentation sheets 0 enclosures)

**Date of issue** 2012-12-19

**Signature**

  
Heribert Schorn  
Director Test Laboratory Bonn



DAT-PL-001 / 91-05

The above-mentioned test results refer to the tested specimen only. The uncertainties of measurement resulting from the measuring methods and the test equipment used have been determined and can be provided on request. No part of the present test report shall be copied or duplicated without prior written consent of the Institute for International Product Safety GmbH (I²PS).

I²PS was awarded with the accreditation by the German Accreditation Body of Technology, DATech e.V. and is authorized to carry out testing in the fields of Industrial low-voltage switchgear and controlgear, Assemblies, Electromagnetic Compatibility (EMC) as well as Environmental tests.



The Test Laboratory Bonn of the Institute for International Product Safety GmbH has been listed in the ALPHA and LOVAG register of approved test laboratories under Identity Number D 01.