



**TREZOR TEST s. r. o.**  
Na Vršku 67, Klecany, Czech Republic

CERTIFICATION BODY No. 3025  
ACCREDITED BY  
THE CZECH ACCREDITATION INSTITUTE

## CERTIFICATE OF CONFORMITY

**Evidence number: TT - 13/2017**

for

**RZ-Products GmbH,  
In der Aue 2, D-57584 Wallmenroth, Germany**

**PRODUCT**  
(identification) Data Security Room  
typ DC-ITRoom GranITe  
Producer: RZ-Products GmbH  
In der Aue 2, D-57584 Wallmenroth, Germany  
CZ-CPA 25.12.10

**CLASSIFICATION**  
(of the product): The product in accordance with the certification schema 1a EN ISO/IEC  
17067:2013


in conformity with requirements of  
EN 1627:2011 Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglar  
resistance – Requirements and classification  
for

### Resistance class RC 3

The certificate is issued on the basis of certification report no. C 275/2016  
within the accreditation according to the certificate no. 750/2016 of 21<sup>st</sup> December 2016 issued by the  
Czech Accreditation Institute.

Chairman of the Certification board  
CB No. 3025  
Ing. Oldřich UHLÍŘ

Date of issue: 12. 01. 2017



Deputy chairman of the Certification board  
CB No. 3025  
Ing. Daniela ČÍŽKOVÁ

Date effective: 12. 01. 2017  
Valid till: 12. 01. 2020

This certificate can be used and duplicated only unchanged.